39° 29.956N / 118° 52.124W WGS84

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104039
Permit No.
Basin 101

NOTICE OF INTENT NO. 56196

1. OWNER JKG
MAILING ADDRESS
ADDRESS AT WELL LOCATION 5615 Caleb Rd Lot 44

2. LOCATION ~~NE~~ SE ¼ NW ¼ Sec. 20 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. Issued by Water Resources | Parcel No. 008-173-10 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		1	14	
Clay		14	34	
Sand Gravels		34	65	
Black Clay		65	72	
Sands, Black		72	86	
Black Clay		86	91	
Clay Beige		91	96	
Gravels		96	113	
Black Grey Clay		113	120	
N 39.499367				
W 118.867754 NAD27				

RECEIVED 2007 JAN -4 AM 10:59 STATE ENGINEERS OFFICE

Date started 12/27/06, 20
Date complated 12/27/06, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30-		2hrs

8. WELL CONSTRUCTION
Depth Drilled 120' Feet Depth Cased 120' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	1.88	1	20
6 5/8	Prc	SH 40	20	120'

Perforations:
Type perforation Saw Cut
Size perforation 1 1/8 x 2 1/2 x 3# rows
From 100 feet to 106 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 120' feet

9. WATER LEVEL
Static water level 20' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Pearson Drilling Inc
Contractor
Address P.O. Box 589
Contractor
S.S. NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed [signature]
By driller performing actual drilling on site or contractor
Date 12/27/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627