

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. SP551

1. OWNER West Ridge Homes ADDRESS AT WELL LOCATION 629 APALOOSA  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SW 1/4 ~~SE 1/4~~ 24 T. 12 N/S R 20 E. Douglas County  
 PERMIT NO. SE 1270-24-01-020 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DIRT-ROCK		0	26	26
BROWN CLAY-GRAVEL		26	38	12
COBBLES		38	76	38
BROWN CLAY		76	156	80
FRAC ROCK		156	197	42
38.88333° N				
119.68205° W				
NAD83				
N 38.883428				
W 119.681057 NAD27				

8. WELL CONSTRUCTION  
 Depth Drilled 197 Feet Depth Cased 197 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 197  
10 5/8 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.88</u>	<u>+1</u>	<u>197</u>
<u>6 5/8</u>	<u>4</u>	<u>SDR 21</u>	<u>17</u>	<u>197</u>

Perforations:  
 Type perforation GRINDER CUT  
 Size perforation .045" X 4"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 157 feet to 197 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 53 ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 53 feet to 197 feet

9. WATER LEVEL  
 Static water level 89 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality CLEAR

Date started 6 APR, 2007  
 Date completed 9 APR, 2007

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25+</u>	<u>00</u>	<u>1.0</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name BLAIN DRILLING & PUMP CO. INC.  
 Address P.O. Box 1255  
Carson City, NV 89702  
 Nevada contractor's license number issued by the State Contractor's Board 46498  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167  
 Signed Jack Dotson  
 Date 25 APR 07