WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104041
Permit No.
Basin 105

NOTICE OF INTENT NO. 57552

1. OWNER West Ridge Homes
MAILING ADDRESS
ADDRESS AT WELL LOCATION 631 APALOOSA

2. LOCATION SW ¼ ~~NW~~ SE ¼ Sec. 24 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. Issued by Water Resources 1220-24-801-019 Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| DIRT-ROCK | | 0 | 18 | 18 |
| BROWN CLAY-GRAVEL | | 18 | 30 | 12 |
| COBBLES | | 30 | 69 | 39 |
| BROWN CLAY-ROCK | X | 69 | 150 | 81 |
| FRAC ROCK | X | 150 | 197 | |

38.88389° N
119.68299° W
NAD83

N38.883988
W 119.681997 NAD27

Date started 4 APR, 2007
Date complated 5 APR, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25+ | | 1.5 |

2007 MAY 24 PM 3:00

8. WELL CONSTRUCTION
Depth Drilled 197 Feet Depth Cased 197 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 10 5/8 | 0 | 197 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 14 | .188 | +1 | 17 |
| 6 5/8 | 4 | SDR21 | 17 | 197 |

Perforations:
Type perforation GRINDER CUT
Size perforation .045" X 4"
From 157 feet to 197 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 51 ft
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 51 feet to 197 feet

9. WATER LEVEL
Static water level 92 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BLAIN DRILLING & PUMP CO. INC. Contractor
Address P.O. Box 1250 Carson City, NV 89702 Contractor
Nevada contractor's license number issued by the State Contractor's Board 46498
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
Signed Jack Dotson
By driller performing actual drilling on site or contractor
Date 25 APR 07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627