COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104043
Permit No.
Basin 107
NOTICE OF INTENT NO. 58250

1. OWNER JERRY JILT CONSTRUCTION
MAILING ADDRESS 2827 PAMALA PL
MINDEN, NV 89423
ADDRESS AT WELL LOCATION 150 SUNDANCE
WELLINGTON, NV 89444

2. LOCATION ~~NE~~ ¼ ~~SW~~ ¼ Sec 7 T 11 N R 24 E LYON County
PERMIT NO. SE NW (Issued by Water Resources) | 010-401-16 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	6	6
BROWN SANDS		6	42	36
GRAY SILTY CLAY		42	228	186
SMALL GREEN SANDS		228	238	10
GRAY GUMMY CLAY		238	320	82
SMALL GREENS SANDS	XXX	320	400	80
SMALL GRAVELS				
N38.834704				
W 119.337757 NAD27				
GPS INFO: NAD 83				
38.83461*N				
119.33874*W				

Date started 3/28, 20 07
Date completed 4/16, 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50*	120	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 400' Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 3/4 Inches	0 Feet	400 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	14.65	.188	+2	400

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 320 feet to 340 feet
From 360 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 400 feet

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 165 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature]
By driller performing actual drilling on site or contractor
Date 4/28/07

RECEIVED 2007 MAY -7 PM 1:03 STATE ENGINEER'S OFFICE