STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104050
Permit No.
Basin 071

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59485

1. OWNER Bill Sovinsky
MAILING ADDRESS 2739 Garder Lane Carson City NV 89706

ADDRESS AT WELL LOCATION 3750 Lupin Drive
Winnemucca, NV 89445
Subdivision Name: County: Humboldt

2. LOCATION NE ¼SE¼ Sec13TN35 /S RE37E
PERMIT/WAIVER NO. 13-581-16
Issued by Water Resources Parcel. No.

Latitude N40°54.469 UTM E ☐ NAD 27
Longitude W117°45.522 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	2	2
Hard rock		2	8	6
cobles & gravel		8	82	74
hard rock		82	87	5
cobles & gravel		87	105	18
clay & gravel		105	115	10
cobles		115	140	25
clay & sand		140	160	20
cobles & gravel	X	160	195	35
boulders		195	200	5

N 40.907928
W 117.757731 NAD27

Date started: April 25, 20 07
Date completed: April 30, 20 07

7. Water Level
Static water level: 146' feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: cool °F
Quality: fair

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12-15		4

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	1.88	+1	20
6.625	4.06	.316	20	200

Perforations:
Type of perforation Factory Cut
Size of perforation 050
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 200 ☐ Pumped ☒ Poured
Type: 3/8
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed Fred Anderson Drilling, Inc.
By driller performing actual drilling on site or contractor
Date May 2, 2007

2007 MAY -3 AM 11:21

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com