STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104051
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59691

1. OWNER RAYMOND FULLER
MAILING ADDRESS 182 W. BULLION ROAD, UNIT 12
ELKO, NV 89801

ADDRESS AT WELL LOCATION 4449 HAMILTON STAGE ROAD
ELKO, NV 89801
Subdivision Name: PARCEL 1 County: ELKO

2. LOCATION NE ¼ NW ¼ Sec 28 T 34N N/S R 55 E
PERMIT/WAIVER No. 006-09H-100
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 11T 0602230 ☐ NAD 27
N 4518069 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	3	3
RED SOIL & GRAVEL MIX		3	20	17
GRAVEL MIX & GRAY SHALE	80	20	150	130
	140			
BLACK HARD ROCK		150	155	5

N40.807362
W115.787072 NAD27

Date started: 30-Apr , 20 07
Date completed: 1-May , 20 07

9. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 3/4	Inches	0	Feet	155	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	18.64	.188	+1	15
8 5/8	22.35	.250	15	155

Perforations:
Type of perforation MACHINED MILL SLOT
Size of perforation 3/16" X 3", 8 ROW
From 135 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 5 to 15 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 155 ☐ Pumped ☒ Poured
Type: 3/8" WASHED PEA GRAVEL
Bentonite Chips: ☒ Yes ☐ No 15 to 50 ☐ Pumped ☒ Poured
Type: 3/8" CHIP

7. Water Level
Static water level: 84 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		2.5

STATE ENGINEER'S OFFICE
2007 MAY 24 AM 11:32
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC.
Contractor
Address P. O. BOX 850
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1689
Signed
by driller performing actual drilling on site or contractor
Date 5/9/2007

(Rev 05-06)

USE ADDITIONAL SHEETS IF NECESSARY