STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104061
Permit No.
Basin 048

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59683

1. OWNER DAVID RICHEY
MAILING ADDRESS 6257 ELTON AVE
LAS VEGAS, NV 89107

ADDRESS AT WELL LOCATION LAKE VIEW DRIVE
Subdivision Name: LUCKY NUGGET #3 County: ELKO

2. LOCATION NW ¼ SW ¼ Sec 9 T 32N N/S R 55 E
PERMIT/WAIVER No. 006-07C-009
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 11T 0602126 ☐ NAD 27
N 4502956 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
GRAVEL & ASH		1	6	5
GRAVEL & SILTSTONE		6	40	34
LIMESTONE		40	210	170
RED SHALE		210	300	90
LIMESTONE	400	300	440	

N40.671256
W 115.790773 NAD27

Date started: 20-Mar, 20 07
Date completed: 22-Mar, 20 07

9. WELL CONSTRUCTION
Depth Drilled 440 Feet Depth Cased 440 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	440	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13.	.188	+1	440

Perforations:
Type of perforation MACHINE MILL SLOT
Size of perforation 3/16" X 3", 6 ROW
From 420 feet to 440 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 5 to 15 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 440 ☐ Pumped ☒ Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: ☒ Yes ☐ No 15 to 50 ☐ Pumped ☒ Poured
Type: 3/8" CHIPS

7. Water Level
Static water level: 312 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		4

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1689
Signed (By driller performing actual drilling on site or contractor)
Date 3-29-07

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY