WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 1041066
Permit No.
Basin 054

NOTICE OF INTENT NO. 58616

1. OWNER Newmont
MAILING ADDRESS PO Box 388
Valmy, Nevada 89438

ADDRESS AT WELL LOCATION
BW-1 Copper Basin

2. LOCATION SW ¼ SW ¼ Sec. 28 T. 32 (N)/S R. 44 E. Lander County

PERMIT NO. M/O 651-B (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| N40.612321 | | | | |
| W117.030451 NAD27 | | | | |
| Materials Used to Abandon Hole | | | | |
| 8- 94lbs Bags Portland Cement at 5.2 Gallons water per Bag. | | | | |
| Latitude: 40.61222076 92 | | | | |
| Longitude: 117.0313949 58 | | | | |
| | | | NAD83 | |

Date started November, 28, 2006
Date completed November, 28, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 407 Feet Depth Cased 407 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | PVC | Sch 80 | 0 | 265 |
| 1 | PVC | Sch 80 | 0 | 286 |

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 176 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Elkins Drilling Co.
Address (Contractor) PO Box 2748
Elko Nevada 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2100
Signed (By driller performing actual drilling on site or contractor)
Date 11-28-06

2007 MAY 29 AM 11:32 STATE ENGINEER'S OFFICE

2006 DEC 15 AM 10:35 RECEIVED STATE ENGINEER'S OFFICE

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627