STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104089
Permit No.
Basin 0348

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59681

1. OWNER JERRY ROBINSON
MAILING ADDRESS 1001 LOWER SOUTH FORK, UNIT 7
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION 2828 FINCH STREET
SOUTH FORK RESERVOIR
Subdivision Name: LUCKY NUGGET #1 County: ELKO

2. LOCATION SE ¼ NE ¼ Sec 15 T 32N N/S R 55 E
PERMIT/WAIVER No. 027-008-005
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 11T 0604756 ☐ NAD 27
N 4501923 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
SAND & GRAVEL		2	15	13
GRAVEL & BOULDERS		15	18	3
SAND & GRAVEL		18	40	22
SILTSTONE		40	100	60
GRAVEL & SOME SAND	110	100	120	20

N 40.661622
W 115.759835 NAD27

Date started: 30-Mar , 20 07
Date completed: 2-Apr , 20 07

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 3/4"	Inches	0	Feet	25	Feet
10 5/8"	Inches	25	Feet	120	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	17.	.188	+1	20
6 5/8	13.	.188	20	120

Perforations:
Type of perforation MACHINE MILL SLOT
Size of perforation 3/16" X 3", 6 ROW
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 5 to 100 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No to ☒ Pumped ☐ Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 4.5 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100+		2

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC.
Contractor
Address P. O. BOX 850
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1689
Signed
By driller performing actual drilling on site or contractor
Date 4/4/2007

(Rev 05-06)

USE ADDITIONAL SHEETS IF NECESSARY