REPORT NO. A07.38

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 104094
PERMIT NO.
BASIN 062A

NOTICE OF INTENT NO. 59520

1. OWNER Michael & Daria Graham
MAILING ADDRESS 903 Clark Way, Palo Alto CA 94304

ADDRESS OF WELL 135 Moonstone Lane
Reno, NV

2. WELL LOCATION SW 1/4 ~~NW~~ NE 1/4 SEC. 13 T 22 R 18 E Washoe COUNTY

PERMIT NO PARCEL NO 79-37-111 SUBDIVISION NAME

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
D.G Pink Granite		0	10	10
Hard White Granite & Green		10	130	120
Fractured Pink Granite		130	190	60
Pink Granite- Some Yellow D.G.		190	220	30
Fractured Pink Granite		220	240	20
Green Basalt Like Rock		240	260	20
Salt & Pepper Granite- Some Pink		260	270	10
Mixed Granite White, Black		270		
Pink & Tan		270	320	50
Salt & Pepper Granite		320		
Vertical Fractured		320	590	270
Tanish Pink Granite		590	710	120
Salt & Pepper Granite		710	770	60
Mixed Granite		770	800	30
Salt & Pepper Granite- Some Tan		800	1020	220
Fractured Salt & Pepper Granite		1020	1098	78

Notes : WGS-84 GPS Latitude: N39 46.523 Longitude: W119 54.672

N 39.775647
W 119.910188 NAD27

Date Started 04/19/2007 Date Completed 05/16/2007

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	18		2.15

8. WELL CONSTRUCTION

Depth Drilled 1098' Depth Cased 1098'

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 670 Feet
6 1/8 Inches 670 Feet 1098 Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
5"	9.62	.188	658'	1098'
6 5/8"	12.92	.188	+2'	670'

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 1058 Feet to 1098 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50'
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 670 Feet

9. WATER LEVEL
Static Water Level 800 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 2189

Signed [signature]
By driller performing actual drilling on site or contractor

Dated May 27-2007

STATE ENGINEERS OFFICE 2007 MAY 30 AM 10:58