

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 109097  
 Permit No. \_\_\_\_\_  
 Basin 103

NOTICE OF INTENT NO. 59121

1. OWNER Steve Rose ADDRESS AT WELL LOCATION 6060 MALLOW CARSON CITY, NV  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 NE 1/4 Sec. 23 T. 15 N/S R. 20 E. CARSON County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. 010-09-10 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY-SAND		0	20	20
BROWN CLAY-GRAVEL		20	95	75
DENSE STICKY CLAY		95	120	25
SANDSTONE		120	145	25
UNKNOWN ROCK (LOST CIRCULATION)		<del>145</del>	<del>220</del>	<del>75</del>
FRACTURED ROCK		220	275	55
39.15448° N				
119.69865° W NAD83				
N 39.154582				
W 119.697653 NAD27				

8. WELL CONSTRUCTION  
 Depth Drilled 275 Feet Depth Cased 275 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 50 Feet  
9 7/8 Inches 50 Feet 150 Feet  
6 1/8 Inches 150 Feet 275 Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>71</u>	<u>150</u>
<u>5</u>		<u>.188</u>	<u>135</u>	<u>275</u>

 Perforations:  
 Type perforation Factory milled / TORCH CUT  
 Size perforation 3/32 x 3" / 1/2" x 8"  
 From 130 feet to 150 feet FM  
 From 175 feet to 235 feet TC  
 From 235 feet to 275 feet FM  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 52 Ft  
 Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 52 feet to 150 feet

9. WATER LEVEL  
 Static water level 146 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature HOT °F Quality TINTED

Date started 23 APR 2007  
 Date completed 25 APR 2007

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>10-12</u>	<u>00:08</u>	<u>1.0</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name \_\_\_\_\_ Contractor  
BLAIN DRILLING & PUMP CO. INC.  
 Address P.O. Box 1255 Carson City, NV 89702  
 Nevada contractor's license number issued by the State Contractor's Board 46498  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167  
 Signed Jack Dotson  
 By driller performing actual drilling on site or contractor  
 Date 25 APR 07