WASHOE #

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 104099
Permit No.
Basin 284

NOTICE OF INTENT NO 57352

1. OWNER **John Claypool**
MAILING ADDRESS **5900 Sage Flat Rd**
Reno, NV 89510

ADDRESS AT WELL LOCATION **5900 Sage Flat Rd**
Latitude N 39.81496 WGS 84
Longitude W 119.64778

2. Location **NW** 1/4 **SE** 1/4 **32** Sec **T23** N **R21** E **Washoe** County
PERMIT NO. 46199 PARCEL NO. **076-232-06** SUBDIVISION NAME

3. WORK PERFORMED
New Well | Replace | Recondition
x Deepen | Abandon | Other

4. PROPOSED USE
Domestic | x Irrigation | Test
Municipal/Industrial | Monitor | Stock

5. WELL TYPE
Cable | X Rotary | RV/C
Air | Other | x Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand.		**295**	**335**	**335**
				0
Boulder, gravel.		**335**	**355**	**20**
				0
Sand & clay.		**355**	**375**	**20**
				0
Sand.		**375**	**385**	**10**
				0
Course sand & streaks of clay.		**385**	**514**	**129**
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0

2007 JUL 26 AM 11:18

N39.815072
W 119.646774 NAD27

8. WELL CONSTRUCTION
Depth Drilled **514** feet Depth Cased **514** feet
HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8	inches	**295** feet	**514** feet
	inches	feet	feet
	inches	feet	feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To Feet
8 5/8	**16.9**	**188**	**0**	**514**

Perforations::
Type Perforation **Factory**
Size perforation **3/32 x 3" double**
From **214** feet to **514** feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet
Surface Seal **X** YES No
Depth of Seal feet
Pumped
Poured
Gravel Packed: Yes No x
From feet to feet

Seal Type:
Neat Cement
Cement Grout
Concrete Grout

9 WATER LEVEL
Static water level **151** feet below land surface
Artesian flow **0** GPM **0** P.S.I.
Water Temperature **cold** Degrees F Quality

Date started **6-12** -07
Date completed **6-22** -07

7. WELL TEST DATA
TEST METHOD: Bailer Pump x Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (hours)
200+	349	6

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. **14170**
NV Driller's Lic (on site) **786**
Signed Steve McK
By driller performing actual drilling on site or contractor
Date 7-11 -07