

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34714

1. OWNER PAUL HESSEL GASSER ADDRESS AT WELL LOCATION 6315 W. MESA VISTA, LV. NV. 89118
 MAILING ADDRESS 6315 W. MESA VISTA, LV. NV. 89118
 2. LOCATION NW 1/4 SF 1/4 Sec. 26 T. 21 S. R. 60 E. CLARK County
 PERMIT NO. 74269 163-26-703-013 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE QM
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		0	280	
Gravel + water	X	280	300	
Gravel + Boulders		300	380	
Gravel + water	X	380	400	
Cemented Gravel		400	450	
Gravel + water	X	450	520	

N 36° 05' 38.3
 W 115° 13' 78.5
 NAD 27

DOWN/DWA
 RECEIVED
 OCT 09 2007
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 520 Feet Depth Cased 520 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 50 Feet
9 7/8 Inches 50 Feet 520 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>+2</u>	<u>520</u>
<u>6 1/2</u>	<u>SRD</u>	<u>PVC</u>	<u>480</u>	<u>+1</u>

Perforations:
 Type perforation Factory
 Size perforation .032 Sieve Type
 From 465 feet to 615 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 265 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality _____

Date started 09-26-07, 20
 Date completed 10-09-07, 20

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name VERNON H. DIMICK Contractor
 Address 5360 N. BONITA VISTA ST. Contractor
LV. NV. 89149
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed V. H. Dimick
 By driller performing actual drilling on site or contractor
 Date 10-09-07