

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53777

1. OWNER Pamala Becker ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 11660 Deodae #10994 Osage Rd
Reno NV 89506 Reno NV 89506
 2. LOCATION NE 1/4 NE 1/4 Sec. 18.25 T. 18.21 0/S R 30.18 E. Washoe County
 PERMIT NO. 08619109 Silverknolls Subdivision Name
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--------------------|--------------|------|-----|------------|
| Fill dirt | | 0 | 2 | 2 |
| Clay | | 2 | 22 | 20 |
| Clay sticky | | 22 | 45 | 23 |
| Sand | | 45 | 47 | 2 |
| Clay | | 47 | 59 | 12 |
| Sand | | 59 | 69 | 10 |
| Clay | | 69 | 75 | 6 |
| Sand | | 75 | 87 | 12 |
| Sand & Clay layers | | 87 | 165 | 78 |
| Sand | | 165 | 180 | 15 |
| Course sand | | 180 | 220 | 40 |
| N 39° 66482 | | | | |
| W 119 90480 NAD83 | | | | |
| N 39.664932 | | | | |
| W 119.903790 NAD27 | | | | |

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From 18 Inches To 15 Feet
 From 11 Inches To 220 Feet
 From _____ Inches To _____ Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 3/8</u> | <u>12.9</u> | <u>3/16</u> | <u>0</u> | <u>220</u> |

Perforations:
 Type perforation Saw slot
 Size perforation 3/16
 From 180 feet to 220 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 220 feet

9. WATER LEVEL
 Static water level 62 feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature NA °F Quality NA

Date started 5.29, 2007
 Date completed 6.15, 2007

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|-----------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>50</u> | <u>220</u> | <u>6</u> |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Olenki Drilling & Pump Co.
 Address 15045 Red Rock Rd
Reno NV 89506
 Nevada contractor's license number issued by the State Contractor's Board 30343
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
 Signed John F. Olenki
 By driller performing actual drilling on site or contractor
 Date 6/18/07