


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY
Log No. 104143
Permit No. _____
Basin 108

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57507

1. OWNER Jesus B. Guameras ADDRESS AT WELL LOCATION 13 Sara Circle
MAILING ADDRESS P.O. Box 2946 Yerington, Nv 89447
Mammoth Lakes, Ca 93546 Subdivision Name: _____ County: Lyon

2. LOCATION SW ¼ NW ¼ Sec 9A T 13N N/S R 26 E Latitude N 39.00811 UTM E NAD 27
PERMIT/WAIVER No. 14-601-50 Longitude W 119.08632 N NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil clayish		0	3	3
Brown clay & sand		3	10	7
Fine to coarse sand		10	16	6
Brown clay with coarse sand & small gravel stratas		16	58	42
Brown clay with fine sand stratas		58	87	29
Aluvial fill coarse sand & gravel				
small rock with brown clay stratas		87	113	26
Fine sand with brown clay stratas		113	120	7
Fine to coarse sand		120	132	12
Coarse sand & small gravel	X	132	160	28
<u>N 39.00811</u>				
<u>W 119.08632 NAD27</u>				

9. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0	23
10 5/8 Inches	23	160

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	20
6 5/8	3.63	.280	20	100
6 5/8	4.06	.316	100	160

Perforations:

Type of perforation Factory screen
Size of perforation .032 X 1/4" spacing X 6 rows

From 140 feet to 160 feet

Annular Seal: Yes No

Neat Cement _____ to _____ Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout 0 to 10 Pumped Poured
 ≥30% Bentonite Grout 10 to 50 Pumped Poured

Gravel Pack: Yes No 50 to 160 Pumped Poured
Type: 1/4" to 3/8" round well rock

Bentonite Chips: Yes No _____ to _____ Pumped Poured
Type: _____

Date started: 27-Jul, 2006
Date completed: 28-Jul, 2006

7. Water Level
Static water level: 28 feet below land surface
Artesian Flow: N/A G.P.M. _____ P.S.I. _____
Water Temperature: Cold °F
Quality: Good

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
Air	50	155' Air line	2 hours

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ogden Drilling
Contractor

Address 152 N. Bybee Ln Yerington, Nv 89447
Contractor

Nevada contractor's license number issued by the State Contractor's Board 57011

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 8-5-06