STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104147
Permit No.
Basin 070

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59344

1. OWNER Andrew & Patty Melanovich
MAILING ADDRESS 471 Ida Ave. Winnemucca,NV 89445

ADDRESS AT WELL LOCATION < of Peachtree & Commander 7990 Peachtree
Winnemucca, NV 89445
Subdivision Name: County: Humboldt

2. LOCATION SW ¼ SE ¼ Sec 14 T35N/ R37E
PERMIT/WAIVER NO. 13-312-34
Issued by Water Resources Parcel. No.

Latitude N40°54.093 UTM E ☐ NAD 27
Longitude W117°46.916 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Clay		3	40	37
Sand/Gravel		40	80	40
Clay		80	90	10
Sand		90	100	10
Clay		100	105	5
Sand & Gravel		105	140	35
Course gravel		140	155	15

N 40.901661
W 117.780964 NAD27

Date started: July 2, 20 07
Date completed: July 2, 20 07

7. Water Level
Static water level: 76' feet below land surface
Artesian Flow: n/a G.P.M. n/a P.S.I
Water Temperature: cool °F
Quality: fair

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		6

9. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	155 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	.188	+1	15
6.625	4.06	.316	15	155

Perforations:
Type of perforation Factory Cut
Size of perforation .050
From 135 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 155 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Rd. (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed Fred Anderson Drilling, Inc
By driller performing actual drilling on site or contractor
Date 07/10/07

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com