COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104153
Permit No.
Basin 089

NOTICE OF INTENT NO. 58267

1. OWNER DENNIS HOF
MAILING ADDRESS 5580 MARLOWE DR
WASHOE CITY, NV 89704

ADDRESS AT WELL LOCATION 5605 MADRS
WASHOE CITY, NV 89704

2. LOCATION ~~SW~~ NW ¼ SW ¼ Sec 14 T 16 N R 19 E WASHOE County

PERMIT NO. (Issued by Water Resources) | Parcel No. 055-167-01 | Subdivision Name WASHOE # WL070057

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SANDS		0	18	18
DG SANDS		18	76	58
BROWN CLAY		76	113	37
DG SANDS AND CLAY		113	160	47
SMALL DG GRAVELS	x	160	180	20
DG GRAVELS	xxx	180	220	40

N 39.249745
W 119.822498 NAD27

GPS INFO: NAD 83
39.24964*N
119.82350*W

Date started 6/18, 20 07
Date completed 6/25, 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	35	4 HRS

8. WELL CONSTRUCTION

Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	180 Feet
6 1/8 Inches	180 Feet	220 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	20
6 5/8 sdr 21	4.06	.316 .216	20	180
5	11.56	.188	160	220

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 160 feet to 180 feet
From 180 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 180 feet

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael J. Hack
By driller performing actual drilling on site or contractor
Date 7/7/07