

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 104158
 Permit No. _____
 Basin 089

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58268

1. OWNER CORNER STONE CONSTRUCTION
 MAILING ADDRESS 3140 NYE DR
CARSON CITY, NV 89706

ADDRESS AT WELL LOCATION 4070 EASTLAKE BLVD
CARSON CITY, NV 89704

2. LOCATION NW 1/4 NE 1/4 Sec 37 T 17 N R 20 E WASHOE County

PERMIT NO. SE SW 050-413-09 NEW WASHOE CITY
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

8. WELL CONSTRUCTION

Material	Water Strata	From	To	Thick-ness
BLOW SANDS		0	7	7
BROWN SOFT SANDS		7	45	38
BROWN CLAY AND SANDS		45	63	18
DG SANDS AND GRAVELS		63	94	31
HARD GRANITE HARD BLUE GRANITE		94	125	31
DG SANDS GRANITE VERY HARD AREAS	X	125	180	55
SOLID BLUE GRANITE W/ SMALL SOFT FRACTURES	XXX	180	220	40
GPS Info: NAD 83 39.28876° N 119.76473° W				
N 39.288865 W 119.763729 NAD27				

Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 3/4 Inches	0 Feet 100 Feet
9 7/8 Inches	100 Feet 180 Feet
6 1/8 Inches	180 Feet 220 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	20
6 5/8 sdr 21	4.06	.316	20	180
5	11.56	.188	180	220

Perforations:
 Type perforation FACTORY MILL SLOT
 Size perforation 3 X 3/32
 From 160 feet to 180 feet
 From 200 feet to 220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 55 feet to 180 feet

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING
 (CONTRACTOR)
 Address 20 KIT KAT DRIVE
 (CONTRACTOR)
CARSON CITY, NV 89706

Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905

Signed Michael J. Hall
 By driller performing actual drilling on site or contractor
 Date 7/07/07

Date started 6/27, 20 07
 Date completed 7/3, 20 07

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>40</u>	<u>3 HRS</u>
	<u>22</u>	<u>110</u>	<u>110</u>