WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 104176
Permit No.
Basin 212

NOTICE OF INTENT NO 27238

1. OWNER Nancy Shelly
MAILING ADDRESS 11211 Lonesome Valley Road Leons Calif. 93551
ADDRESS AT WELL LOCATION 1 mile west of mile marker # 104 US 93 North of Caliente

2. LOCATION SE ¼ SW ¼ Sec. 10 T. 3 N/S R. 67 E. Lincoln County
PERMIT NO. -0 Issued by Water Resources
013-150-06 Parcel No.
Highland Knolls Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders-sand		0	80	80
Clay- Boulders		80	190	110
gravel-Boulders-Clay	X	190	270	80
Hard Rock		270	275	5

WGS 84
N 37° 41.792'
W 114° 28.358'

DCNR/DWR
RECEIVED
NOV 26 2007
LAS VEGAS OFFICE

Date started 11-8-07, 20
Date completed 11-15-07, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		2

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	275 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6½	PVC	Sch 40	0	275

Perforations:
Type perforation Saw cut
Size perforation 1/4" x 5"
From 115 feet to 135 feet
From 155 feet to 175 feet
From 195 feet to 215 feet
From 235 feet to 275 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 275 feet

9. WATER LEVEL
Static water level 175 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps Contractor
Address HC 61 Box 54 Hiko NV 89017 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0028866
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis
By driller performing actual drilling on site or contractor
Date

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627