COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104211
Permit No.
Basin 105

NOTICE OF INTENT NO. 60303

1. OWNER BILL MERRILL CONSTRUCTION
MAILING ADDRESS P.O BOX 2262
MINDEN , NV 89423

ADDRESS AT WELL LOCATION 621 MEGAN CT
GARDNERVILLE , NV 89410

2. LOCATION SW ¼ SW ¼ Sec 19 T 12 N R 21 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | 1221-19-002-025 (Parcel No.) | (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
COURSE DG SANDS		0	4	4
SANDS AND GRAVELS		4	93	89
BROWN CLAY		93	103	10
OBSIDIAN GRAVELS		103	186	83
BROWN CLAY		186	264	78
SMALL GRAVELS		264	281	17
FRACTURED GRAVELS	XXX	281	340	59

N 38.882118
W 119.672847 NAD27

GPS INFO: NAD 83
38.88202*N
119.67384*W

Date started 8/13 , 20 07
Date completed 8/17 , 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18	68	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	340	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr 21	4.03	~~.216~~ .316	20	340

Perforations:
Type perforation SAW CUT
Size perforation 3 X 3/32
From 300 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
From 60 feet to 340 feet

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 200 feet below land surface
Artesian flow G.P.M 18 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael F Hack
(By driller performing actual drilling on site or contractor)
Date 8/29/07