

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58582

1. OWNER Terry / BW ADDRESS AT WELL LOCATION MAY 2330 HILLCREST FERNLEY, NV  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SW 1/4 SW 1/4 Sec 29 T. 20 N/S R. 25 E LAMON County  
 PERMIT NO. 021-304-22 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DIRT-ROCK		0	8	8
COBBLES		8	98	90
BLACK FRAC ROCK		98	246	148
3/4" GRAVEL-CLAY		246	488	242
BROWN CLAY-GRAVEL		488	518	30
FRAC ROCK	<del>XXXX</del>	518	700	182
LARGE GRAVEL	<del>XXXX</del>	700	755	55

39.56515° N  
 119.20740° W MAY  
 N 39.565255  
 W 119.206410 NAD27

2007-06-29 AM 2:03  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 755 Feet Depth Cased 755 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 100 Feet  
7 1/8 Inches 100 Feet 500 Feet  
8 3/4 Inches 500 Feet 755 Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>755</u>

Perforations:  
 Type perforation Factory Cut  
 Size perforation 3/32" X 3"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 675 feet to 755 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 56 FT  Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  
 Poured  
 Gravel Packed:  Yes  No  
 From 56 feet to 755 feet

9. WATER LEVEL  
 Static water level 526 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality BAD (ORANGE)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name BLAIN DRILLING & PUMP CO. INC.  
 Address P.O. Box 1255 Carson City, NV 89702  
 Nevada contractor's license number issued by the State Contractor's Board 46498  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167  
 Signed Jack Watson  
 By driller performing actual drilling on site or contractor  
 Date 3 JUNE 07

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>5-6</u>		<u>16</u>