

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104233
Permit No. _____
Basin 269

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58466

1. OWNER Ron Visser ADDRESS AT WELL LOCATION 4050 HWY 95
MAILING ADDRESS PO Box 527 Winnemucca, Nv 89446
Subdivision Name: _____ County: HUMBOLDT

2. LOCATION SE 1/4 SE 1/4 Sec 22 T 38 N/S R 38 E Latitude 41 09.079N UTM E NAD 27
PERMIT/WAIVER No. 0 Parcel No. 006-342-14 Longitude 117 40.749W N X

3. WORKED PERFORMED New Well Replace Recondition Deepen Other
4. PROPOSED USE Domestic Irrigation Test
Municipal/Industrial Monitor Stock
5. WELL TYPE Cable Rotary RVC
Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand & Gravel		0	20	20
sand w/ clay stringers		20	70	50
sand & gravel w/ clay stringers		70	80	10
clay		80	140	60
consolidated granite hard pan w/ clay	X	140	220	80
CG HP w/ more clay	X	220	300	80
	X	300		-300

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
300		300	

HOLE DIAMETER (BIT SIZE)

	From	To	Feet	Feet
10 5/8	0	300		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.5	STEEL	.188	0	20
	PVC	.350	20	300

Perforations:

Type of perforation	Size of perforation	From	To	Feet	Feet
PVC Screen	1/16	260	300		

Annular Seal: Yes

Material	to	to	Pumped	Poured
Neat Cement	4	100	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Cement Grout			<input type="checkbox"/>	<input type="checkbox"/>
Concrete Grout			<input type="checkbox"/>	<input type="checkbox"/>
≥30% Bentonite Grout			<input type="checkbox"/>	<input type="checkbox"/>
Gravel Pack:	<input checked="" type="checkbox"/> Yes	No 80 to 300	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
Type:	3/8 minus			
Bentonite Chips:	<input checked="" type="checkbox"/> Yes	No to	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
Type:	3/8 baroid			

7. Water Level
Date started: 8-6-07
Date completed: 8-7-07
Static water level: 187 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: COLD °F
Quality: _____

8. WELL TEST DATA

TEST METHOD:	Ballor		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	Time (Hours)
AIR	55	50			4	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: High Desert Drilling LLC
Contractor
Address: 4225 E Mary Way
Contractor
Winnemucca Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board: 62237
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 2140
Signed: [Signature]
By driller performing actual drilling on site or contractor
Date: 9-5-07

USE ADDITIONAL SHEETS IF NECESSARY

STATE ENGINEERS OFFICE
2007 SEP -7 AM 11:30
RECEIVED