

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 104241
 Permit No. _____
 Basin 102

NOTICE OF INTENT NO. SR729

1. OWNER Brian Silsby ADDRESS AT WELL LOCATION 7655 ANTELOPE SILVER SPRINGS, NV
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 ~~20~~ 20 17 N/S R 25 E LYON County
 PERMIT NO. 17-481-03 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN SAND		0	26	26
BLACK GRITTY CLAY		26	120	94
BROWN SANDY GRAVEL		120	126	6
COARSE BROWN SAND		126	165	39
FINE-MEDIUM GRAVEL		165	178	13
BLACK SILT		178	180	2
39.32451° N				
119.19943° W NAD83				
N 39.324611				
W 119.198444 NAD27				

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 180 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	1	20
6 5/8	4	SDR-21	20	180

Perforations:
 Type perforation GRINDER CUT
 Size perforation .045" x 4"
 From _____ feet to _____ feet
 From 160 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 53 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 53 feet to 180 feet

9. WATER LEVEL
 Static water level 46 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD F Quality ODOR-SAND

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING & PUMP CO. INC.
 Address P.O. Box 1255 Carson City, NV 89702
 Nevada contractor's license number 46498 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack Dotson
 By driller performing actual drilling on site or contractor
 Date 9 July 07

Date started 5 July 2007
 Date completed 9 July 2007

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25+</u>		

RECEIVED
 2007 SEP 14 AM 10:46
 STATE ENGINEERS OFFICE