

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 104249
Permit No. _____
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

WAIVER NUMBER R-544554
NOTICE OF INTENT NO. KLB 4/13/07

1 OWNER GORDON M. & COLLEEN F. HINDS ADDRESS AT WELL LOCATION STREET ADDRESSES NOT ISSUED BY
MAILING ADDRESS 1278 SORENSEN LANE DOUGLAS Co. YET, WAIT UNTIL PROJECT IS FINALED & ACCEPTED
GARDNERVILLE, NV 89460 Subdivision Name: SORENSEN SUBDIVISION County: DOUGLAS

2 LOCATION NE 1/4 NW 1/4 Sec 16 T 12 N R 20 E Latitude UTM E 1469124.01 NAD 27
PERMIT/WAIVER No. R-544554 Longitude N 2294501.13 NAD 83/WGS 84
APN 1220-16-101-010 Issued by Water Resources Parcel No. ORIGINAL PARCEL ADDRESS BEFORE SUBDIVISION 1278 SORENSEN LANE

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? NO
If yes, what is replacement well NOI? _____

Is there an existing well log? NOT KNOWN
If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION
Depth Drilled 85 Feet Depth Cased 85 Feet

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8"</u>	<u>NOT KNOWN</u>			

Existing Perforations:
Type of perforation NOT KNOWN
Size of perforation NOT KNOWN

From	feet to	feet	feet
<u>0</u>		<u>85</u>	

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: WELL CASING WAS CAPPED WHEN FOUND, APPEARED CLEAN AND WAS DRY TO MEASURED BOTTOM DEPTH OF 85 FEET

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

If casing was left in place, please show where additional perforations were made:
Additional Perforations: NONE
Type of perforator used:
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____

5 WATER LEVEL
Static water level DRY feet below land surface
Artesian flow NONE G.P.M. NOT KNOWN P.S.I.
Water temperature _____ °F Quality _____

6 Additional Notes or Comments
ON TUESDAY 4/13/07 THE AREA AROUND THE CASING WAS EXCAVATED TO APPROX. 6 FEET BELOW EXISTING FINISH GRADE.
ON MONDAY 4/16/07 5 FEET OF THE CASING WAS CUT OFF AND THE CASING WAS FULLED FULL WITH BING MATERIAL C55 READY MIX, MIX DESIGN ATTACHED.
ON TUESDAY 4/17/07 THE EXCAVATION WAS BACKFILLED AND COMPACTED TO MATCH THE SURROUNDING FINISH GRADE.

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<u>0</u>	<u>80</u>	<u>feet</u>	<u>C55</u>		

Neat Cement Fluid Weight _____ lbs/gal
Bentonite Grout _____ % bentonite

Date Started 4/13/07
Date Completed 4/17/07

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge. RONALD D. KIPP
Name MILES CONSTRUCTION, INC. Contractor
Address 601 INDUSTRIAL PARKWAY Contractor
CARSON CITY, NV 89706
Nevada contractor's license number _____
issued by the State Contractor's Board A 65971
Nevada driller's license number issued by the _____
Division of Water Resources, the on-site driller
Signed Ronald D Kipp
By driller performing actual drilling on site or contractor
Date 8/08/07

USE ADDITIONAL SHEETS IF NECESSARY