STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104251
Permit No.
Basin 054

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60393

1. OWNER Ralph Lico
MAILING ADDRESS 394 Enterprise Rd.
Hollister CA 95023

ADDRESS AT WELL LOCATION Crescent Valley Ranch
Subdivision Name: County: Eureka

2. LOCATION NW ¼ SE ¼ Sec 29 T 29N N/S R 48 E
PERMIT/WAIVER No. 003-141-21
Issued by Water Resources Parcel No.

Latitude 40.21.156N
Longitude 116.34.690W
UTM E N
☐ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	64	64
Sand and Gravel	X	64	65	1
Sandstone		65	81	16
Sand and Gravel	X	81	120	39

N 40.352694
W 116.577240 NAD27

RECEIVED 2007 SEP 20 AM 11:04 STATE ENGINEERS OFFICE

Date started: 16-Aug, 20 07
Date completed: 18-Aug, 20 07

7. *Water Level*
Static water level: 28 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	100		6.5

9. *WELL CONSTRUCTION*
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
105/8	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+3	120

Perforations:
Type of perforation Mill Slot
Size of perforation 3/16 X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 53 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 53 to 120 ☐ Pumped ☒ Poured
Type: 3/8 PEA GRAVE;
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR. dba FERTIG DRILLING COMPANY
Contractor
Address P.O. BOX 525
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 031904
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1584
Signed
By driller performing actual drilling on site or contractor
Date 9-13-07

(Rev. 05-05)

USE ADDITIONAL SHEETS IF NECESSARY