WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104280
Permit No.
Basin 102

NOTICE OF INTENT NO. 59879

1. OWNER Gary Scrimpsher
MAILING ADDRESS
ADDRESS AT WELL LOCATION 2050 Fir St. Silver Springs, NV 89429

2. LOCATION SE ¼ SE ¼ Sec. 35 T. 18 N/S R. 24 E Lyon Co County
PERMIT NO. Issued by Water Resources | 15211-45 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air [redacted]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Air Drilled Hole to 240' feet				
Hole was Caving in on us.				
No water was in Hole.				
Clay & Sand		0	4'	
Gray Clay & Sand		4	26'	
Yellow Clay-Sand		26'	60'	
Fractured Basalt		60	130'	
Hard Basalt		130'	163'	
Fractured Basalt		163'	220'	
Hard Basalt		220'	275	
Fractured Basalt	✓	275	303'	
GPS, WGS 84				
N39°22.535				
W 119°15.123				
3 days waited to Start				
RTI Mark. S				
N 39.375685				
W 119.251062 NAD27				

Date started Aug 17/07, 20
Date completed Aug 25/07, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30 Gpm	4 Hrs.	

8. WELL CONSTRUCTION
Depth Drilled 303 Feet Depth Cased 304' (303) Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	60' Feet
8 3/4 Inches		60 Feet	240' Feet
6" Inches		240 Feet	303' Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13 lbs	.185	+1	242'
4" PVC	PVC	Sch 40	200'	300'

Perforations:
Type perforation Sawed
Size perforation 1/8 X 2"
From feet to feet
From 240' feet to 300 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 240' feet

RECEIVED 2007 SEP 21 AM 11:22 STATE ENGINEER'S OFFICE

9. WATER LEVEL
Static water level 140' feet, feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Frank Drilling Inc. Contractor
Address PO Box 599 Contractor
Silver Springs, NV 89429
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed [signature] By driller performing actual drilling on site or contractor
Date Sept 20/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627