WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104281
Permit No.
Basin 102

NOTICE OF INTENT NO. 59897

1. OWNER Gary Scrimpsher
MAILING ADDRESS
ADDRESS AT WELL LOCATION 2050 Fir St. Silver Springs NV. 89429

2. LOCATION SE ¼ SE ¼ Sec. 35 T. 18 N/S R. 24 E. Lyon, Co County
PERMIT NO. Issued by Water Resources | Parcel No. 15-211-45 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Casing Caved in at 97 feet to 148' feet. Well Went Dry.				
Cleaned out to 240' feet and Tryed to pull 6" Casing. it would not pull.				
Then we set pipe to 240 feet and pluged with abonite to 20 feet from surface. Then pluged with Neat Cement to surface. Cut off Casing.				
GPS. WGS 84 N 39° 22.530 W 119° 15.123				
3 days Waved to Start				
Att: Mark, S				

Date started Aug 16/07, 20
Date complated Aug 17/07, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		N39,375602	
		W119,251062	NAD27

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)
From To
Inches Feet Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6				

RECEIVED 2007 SEP 21 AM 11:22 STATE ENGINEERS OFFICE

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 2
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level None-dry feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc
Contractor
Address PO Box 599
Contractor
Silver Springs NV. 89429
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed [signature]
By driller performing actual drilling on site or contractor
Date Sept 19/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627