STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104293
Permit No.
Basin 044

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60396

1. OWNER LaRue Green
MAILING ADDRESS 505 Copper St. #605
Elko, Nv 89801

ADDRESS AT WELL LOCATION 7743 Jacinto Lot 5 Block 14
Subdivision Name: County: Elko

2. LOCATION NW ¼ SE ¼ Sec 31 T 36N N/S R 57 E
PERMIT/WAIVER No. 012-014-005
Issued by Water Resources Parcel No.

Latitude 40.57.597N
Longitude 115.35.353W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Soft Sandstone Clay Mix		5	140	135
Clay		140	160	20
Gravel and Sand	X	160	188	28

RECEIVED 2007 SEP 20 AM 11:04 STATE ENGINEERS OFFICE

N 40.960044
W 115.588310 NAD27

Date started: 6-Sep, 20 2007
Date completed: 7-Sep, 20 2007

7. Water Level
Static water level: 95 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	40		6

9. WELL CONSTRUCTION
Depth Drilled 188 Feet Depth Cased 188 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
105/8	Inches	0	Feet	188	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	188

Perforations:
Type of perforation Mill Slot
Size of perforation 3/16 X 3"
From 168 feet to 188 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 54 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 54 to 188 ☐ Pumped ☒ Poured
Type: 3/8 PEA GRAVE;
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR. dba FERTIG DRILLING COMPANY
Contractor
Address P.O. BOX 525
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed
By driller performing actual drilling on site or contractor
Date 9-13-07

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY