

Log No. 104299
 Permit No. _____
 Basin 180

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25354

1. OWNER Bill Mull ADDRESS AT WELL LOCATION North Cave Valley
 MAILING ADDRESS P.O. Box 195
Enterprise, UT 84725

2. LOCATION NE 1/4 NW 1/4 Sec 16 T 9 N/R 64 East Lincoln County
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. 005-021-010 District 5 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|--------------------|--------------|------|-----|-----------|
| Cobbles, Boulder | | 0 | 10 | 10 |
| Brown Limestone | | 10 | 80 | 70 |
| White Quartzite | | 80 | 155 | 75 |
| Brown Limestone | | 155 | 205 | 50 |
| Pink Limestone | | 205 | 230 | 25 |
| 5% Clay, Limestone | | 230 | 260 | 30 |
| Gray Limestone | ✓ | 260 | 400 | 140 |

(From NAD)
 N 38° 38' 33.7"
 W 114° 47' 57.1" NAD27

N 38.642694
 W 114.799194 NAD27

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches 0 Feet 400 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-------------------|
| 6.625 | 17.02 | .250 | + 18" | 400 20 |
| 6.625 | 5.006 | .390 | 20 | 400 |

Perforations:
 Type perforation Mill
 Size perforation 1/8"

From 280 feet to 300 feet
 From 320 feet to 340 feet
 From 360 feet to 380 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout 3150 lbs.

Gravel Packed: Yes No
 From 100 feet to 400 feet

9. WATER LEVEL
 Static water level 240 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 48 °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Gardner Brothers Drilling, Inc. Contractor
 Address P.O. Box 965 Contractor
Enterprise, UT 84725
 Nevada contractor's license number issued by the State Contractor's Board 0068459
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1710
 Signed Dale Gardner
 By driller performing actual drilling on site or contractor
 Date 9-20-07

Date started August 30, 2007
 Date completed September 14, 2007

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| TEST METHOD | G.P.M. | Draw Down (Feet) | Time (Hours) |
|-------------|--------|------------------|--------------|
| 9-17-07 | 20 | - | 1 HOUR |

RECEIVED
 2007 SEP 24 PM 1:21