

STATE OF NEVADA
DIVISION OF WATER RESOURCES



OFFICE USE ONLY

Log No. 104302
Permit No. _____
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please fill in this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60523

1. OWNER Carl Brooks
MAILING ADDRESS 2171 W. Williams Fallon, NV 89406
Fallon, NV 89406

ADDRESS AT WELL LOCATION 1625 Melanie
Fallon, NV 89406

2. LOCATION SE 1/4 NE 1/4 Sec 20 T 19 R 28
PERMIT NO Parcel No. 008-191-47

Latitude 39.49695 Longitude -118.86048 WGS 84
Subdivision Name _____ County Churchill

3. WORK PERFORMED
Replace

4. PROPOSED USE
Domestic

5. WELL TYPE
Rotary-mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	12	12
Brown Clay		12	14	2
Brown Sand		14	48	34
Black Sand		48	50	2
Brown Sand	X	50	61	11

N 39.497051
W 118.859501 NAD27

8. WELL CONSTRUCTION

Depth Drilled 61 Depth Cased 61 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12.3 Inches	0 Feet	17 Feet
10 Inches	17 Feet	61 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (inches)	Weight/Pt. (Pounds)	Wall Thickness	From (Feet)	To (Feet)
6.625	12.92	0.188	0	17
6	4.0	0.316	17	61

Perforations:

Type perforation Saw Cut
Size perforation 0.125
From 57 feet to 61 feet

Surface Sea Yes No

Seal Type:

Depth of Seal 50

Concrete Grout

Placement Method: Pumped

Gravel Packed: Yes No

From 50 feet to 61 Feet

9. WATER LEVEL

Static Water Level 8 feet below land surfac

Artesian Flow G.P.M. P.S.I.

Water temperature ° F Qualit unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.

Contracto

Address 403 McLean Road

Fallon, NV 89407

Contracto

Nevada contractor's license number 29064
issued by the State Contractor's

Nevada driller's license number issued by the 2307
Division of Water Resource, the on-site driller

Signe *[Signature]*

By driller performing the actual drilling on site or contract

Date 9/19/2007

Date started 9/12/2007

Date completed 9/12/2007

7. WELL TEST DATA

TEST METHOD Air

Comments	GPM	Drawdown	Time (Hours)
	10		1

STATE ENGINEERS OFFICE

2007 SEP 24 PM 1:24

RECEIVED