STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104305
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60671

1. OWNER Ceasar Gil
MAILING ADDRESS P.O. Box 955
Carlin, NV 89822

ADDRESS AT WELL LOCATION 5828 Limousine Drive
Subdivision Name: MVR #3 County: Elko

2. LOCATION NW ¼ SE ¼ Sec 3 T 35N N/S R 56 E
PERMIT/WAIVER No. 035-066-018-004
Issued by Water Resources Parcel No.

Latitude 40 4.56.885N
Longitude 115.39.152W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	3	3
Sandstone		3	151	148
Clay		151	160	9
Sand & Gravel	X	160	188	28
Clay		188	200	12

N 40.548178
W 115.651625 NAD27

Date started: 5-Sep, 20 07
Date completed: 6-Sep, 20 07

7. Water Level
Static water level: 64 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	45		4

STATE ENGINEERS OFFICE
2007 SEP 27 AM 11:59
RECEIVED

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	200
6		SDR-17	20	200

Perforations:
Type of perforation screen
Size of perforation 0.032
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 20 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☒ Poured
Gravel Pack: ☒ Yes ☐ No 54 to 200 ☐ Pumped ☐ Poured
Type: 3/8 PEA GRAVE;
Bentonite Chips: ☒ Yes ☐ No 20 to 54 ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR. dba FERTIG DRILLING COMPANY
Contractor
Address P.O. BOX 525
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed
By driller performing actual drilling on site or contractor
Date 9-14-07

(Rev. 05-09)
USE ADDITIONAL SHEETS IF NECESSARY