WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104315
Permit No.
Basin 179

NOTICE OF INTENT NO. 59448

1. OWNER Mike Pintar
MAILING ADDRESS POB 796
McGill, NV 89318

ADDRESS AT WELL LOCATION McGill Flat

2. LOCATION NE ¼ SW ¼ Sec. 6 T. 17 N/S R. 64 E. White Pine County
PERMIT NO. (Issued by Water Resources) APN 10-300-06 (Parcel No.) McGill Flat (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Course Sand & Gravel		3	15	12
Sand & Sm. Gravel		15	25	10
Sand & Gravel		25	40	15
Course Water Gravel	x	40	47	7
Sand & Sm. Gravel		47	85	38
Brown Clay		85	95	10
Course Water Gravel	x	95	105	10
Brown Clay		105	110	5
Course Water Gravel	x	110	130	20
Fine Sand & Sm. Gravel		130	155	25
Brown Clay		155	160	5

N 39.367011
W 114.818442 NAD27

WGS 84
N 39° 22' 01.0"
W114° 49' 09.5"
Elev. 6,120 ft.

Date started August 15, 20 07
Date complated August 22, 20 07

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
125	113	1

RECEIVED
2007 SEP 27 AM 11:11
STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10-5/8	0	160

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	160

Perforations:
Type perforation Factory
Size perforation 1/8" x 2 1/2" 6 Rows
From 80 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 37 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Ave. (Contractor)
Ely, NV 89301

Nevada contractor's license number issued by the State Contractor's Board 14790

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793

Signed Rick Lewis By Jerald D. Christiansen
(By driller performing actual drilling on site or contractor)

Date September 17, 2007

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627