COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104317
Permit No.
Basin 105

NOTICE OF INTENT NO. 60305

1. OWNER MARION WELLER
MAILING ADDRESS 2659 GORDON LN
MINDEN, NV 89423

ADDRESS AT WELL LOCATION 2659 GORDON LN
MINDEN, NV 89423

2. LOCATION ~~SW~~ ¼ SW ¼ Sec 34 T 14 N R 20 E DOUGLAS County

PERMIT NO. NE (Issued by Water Resources) | 1420-34-310-027 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
COURSE DG SANDS		0	8	8
BROWN CLAY		8	63	55
DG SANDS SILTY		63	110	47
BROWN GUMMY CLAY		110	133	23
SMALL GRAVELS	XXX	133	180	47

GPS INFO: NAD 83
39.03176* N
119.72854*W

N 39.031861
W 119.727543 NAD27

Date started 8/28, 20 07
Date completed 8/30, 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	45	3 HRS

RECEIVED 2007 SEP 26 AM 11:09 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	180 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	180

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 60 ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 60' feet to 180 feet

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael J. Lorek
By driller performing actual drilling on site or contractor
Date 9/14/07