

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58661

1. OWNER Nevada Power ADDRESS AT WELL LOCATION 2 miles north of Iages Station in White Pine Cnty  
 MAILING ADDRESS P.O. Box 98910 Las Vegas, NV. 89151

2. LOCATION NE 1/4 S W 1/4 Sec. 27 T 26 Q/S R 65 E White Pine County  
 PERMIT NO. Waiver R-550/21824 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material  | Water Strata | From | To | Thick-ness |
|---|--------------|------|----|------------|
| Attempted to measure water level but could not get beyond 47'. There was 6' of turbine pump shaft sticking out the top of the well. We tried to remove the pump by pulling on the shaft but could not remove it. We conducted a video of the and found large holes in the casing from 20' to 37' where we could not advance the camera further due to the pump shaft lodging the camera. There was no gravel pack behind the casing where the holes were. Since we could not get past 47' we poured in 15 yards of neat cement and filled the well. |              |      |    |            |
| GPS location: 40.099N & 114.62W   |              |      |    |            |
| original log attached   |              |      |    |            |
| <u>log # 9775</u>   |              |      |    |            |

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Pt. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 16"                |                     | .250                    | +1          | 300'      |

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 300  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level: n/a feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 7/25/07  
 Date completed 8/15/07

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
|        |                               |              |

2007 OCT 11 AM 11:07  
 RECEIVED

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Carson Pump Contractor  
 Address P.O. Box 20159 Carson City, NV. 89721 Contractor  
 Nevada contractor's license number 39920 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1482  
 Signed Don Thompson By driller performing actual drilling on site or contractor  
 Date 10/8/07