

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56583

1. OWNER Nevada Department of Agriculture - 350 ADDRESS AT WELL LOCATION US Forest Service Land Toyn Creek, Harrison Pass, Elko County, Nv. HA 047  
 MAILING ADDRESS Capitol Hill Ave Reno, Nv 89502  
 2. LOCATION SW 1/4 NE 1/4 Sec. 09 T 28 N 57 E Elko County  
 PERMIT NO. M10-1468 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface-Grassy meadow				
Fine Brown loam		0	3	3
Soft, dark black moist clay		3	4	1
Rock		4	4 1/2	1/2
Clay		4 1/2	6	1 1/2
Black, saturated pea gravelly clay	(G)	6	16	10
Rock		16	16 1/2	1/2
Tan Sandy Clay NO WATER		16 1/2	20	3 1/2
GPS Location: As Drilled				
40 19 27.9	NAD	83		
115 33 26.1				
± 17 feet				
N40.324503				
W 115, 556353 NAD07				

8. WELL CONSTRUCTION  
 Depth Drilled 20 Feet Depth Cased 19 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 20  
6 5/8 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2-inch	PVC	Schedule 40	0	20
Flush Threaded				

 Perforations:  
 Type perforation Slot  
 Size perforation 0.020 inch  
 From 10 feet to 15 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0 to 1 foot  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 8 feet to 20 feet


9. WATER LEVEL  
 Static water level 1.73 feet below land surface  
 Artesian flow NO G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_


10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name R.N. Pennington  
 Address 2730 N. Deer Run Rd. Carson City, Nv 89701  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller FP-1857  
 Signed R.N. Pennington  
 By driller performing actual drilling on site or contractor  
 Date 9-28-07

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

114332 Pg 2





Coral Creek  
 Township: 28 N  
 Range: 56 E  
 Section: 13

Coral Creek  
 Township: 28 N  
 Range: 57 E  
 Section: 9

0 0.25 0.5

Toyn Creek Well

104332 754

HA 047 T28N R57E Sec 9 SW 1/4 NE 1/4

Notice of Intent # 56583

M/O # 1468

GPS Location 401927.9 NAD 83

1153326.1

± 17'

Map: Harrison Pass 1:24,000

To Spring Ck.

Jiggs



3.9 miles

Harrison Pass Road

Pond

Zaga Ranch

USFS Trail # 357

# 359

Well

Toyn Creek

Harrison Pass

3/20/04

— Toyn —



Figure 2 Toyn Creek well: the photo was taken facing west. That is the old Harrison Pass road on the right. Toyn Creek is 10 or so yards to the left of the well.

HA 047 T 28N R 57E Sec 09 SW 1/4 NE 1/4

— Site Before Well Drilled —