

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59447

1. OWNER Bob & Leslie Schumacker ADDRESS AT WELL LOCATION 285 N. Elk Springs Rd.
 MAILING ADDRESS 3325 Hyannis Circle
Las Vegas, NV 89129

2. LOCATION SW 1/4 NE 1/4 Sec. 7 T. 16 N/S R. 65 E. White Pine County
 PERMIT NO. APN 10-810-07 Elk Springs Estates
 Issued by Water Resources Parcel No. 4A Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	3
Red Clay w/ Limestone		3		
Boulders			15	12
Red Clay		15	30	15
Red Altered Limestone		30	60	30
Shale w/ Clay Stringers		60	80	20
Limestone		80	95	15
Fractured Altered Limestone	x	95		
Limestone			105	10
Altered Limestone		105	183	78

N 39.267537
W 114.700058 NAD27

WGS 84
 Lat. N 39° 16' 02.9"
 Long. W 114° 42' 03.3"
 Elevation 8,723

8. WELL CONSTRUCTION
 Depth Drilled 183 Feet Depth Cased 183 Feet

HOLE DIAMETER (BIT SIZE)
 From 10-5/8 Inches To 0 Feet 183 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6-5/8</u>	<u>12.92</u>	<u>.188</u>	<u>0</u>	<u>183</u>

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 6 Rows
 From 83 feet to 183 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet feet to 183 feet

Date started August 29, 2007
 Date completed September 19, 2007

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>110</u>	<u>1 1/2</u>

2007 OCT -4 PM 2:06
 RECEIVED

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Ave. Contractor
Ely, NV 89301
 Nevada contractor's license number 14790
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1793
 Division of Water Resources, the on-site driller
 Signed Richard Lewis By Jerald D. Christiansen
 By driller performing actual drilling on site or contractor
 Date October 1, 2007