

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60149

1. OWNER B & B INVESTMENTS ADDRESS AT WELL LOCATION Pickering Ave
 MAILING ADDRESS 555 Pine St. Elko, NV 89801

2. LOCATION NW 1/4 SW 1/4 Sec 15 T. 32 N 1/2 R 55 E Elko County _____
 PERMIT NO. N/A Issued by Water Resources Parcel No. 027-020-008 Subdivision Name Lucky Moppel Estates

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil		0	2	2
Sand & clay		2	16	14
Clay, sand, gravel		16	18	2
Sand, gravel, boulders		18	26	8
Sand, gravel, clay		26	32	6
White sandy clay		32	50	18
Tan sandy clay		50	115	65
White sandy clay	5gpm	115	121	6
Clay		121	133	12
Sand, gravel & clay	5gpm	133	134	1
Clay		134	140	
Blue clay		134	180	
T.D. 180				
G.P.S. 40.65567 N. NAD 27 115-77083 W				

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

From	To
12 Inches	0 Feet 35 Feet
10 Inches	35 Feet 50 Feet
8 Inches	50 Feet 180 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	11	180

Perforations:
 Type perforation Torch Cut
 Size perforation 1/8 x 4"

From	To
112 feet	145 feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 51
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 51 feet to 170 feet

9. WATER LEVEL
 Static water level 72 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I. _____
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MUTH DRILLING Co. Contractor
 Address 203 PINE ST., ELKO, NV 89801 Contractor

Date started 7-10-07, 19____
 Date completed 8-8-07, 19____

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	73	5:25

RECEIVED
 2007 OCT 11 AM 11:02
 STATE ENGINEER'S OFFICE

Nevada contractor's license number issued by the State Contractor's Board 10819
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
 Signed James V. Muth
 By driller performing actual drilling on site or contractor
 Date 8-8-07