

OFFICE USE ONLY  
 Log No. 104383  
 Permit No. \_\_\_\_\_  
 Basin 207

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59930

1. OWNER Kerrick-Deanne Ivins ADDRESS AT WELL LOCATION Lot 1 Block 2  
 MAILING ADDRESS Po Box 711  
Land NV 89317 N 38° 52' 07.6"  
W 115° 01' 13.00"  
 2. LOCATION NE 1/4 SE 1/4 Sec. 29 T. 12 N/S R. 62 E. White Pine County  
 PERMIT NO. N/A Parcel No. 013-101-05 Subdivision Name Land ten acre plat

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silt clay-gravel		0	12	
gravel		12	13	
Silt clay		13	30	
gravel	water	30	31	1
gravel-clay		31	33	
gravel	water	33	35	2
Silt clay		35	51	
Sand gravel	water	51	60	9
Silt clay		60	80	
Sand gravel	water	80	95	15
Clay		95	100	

N 38.868778  
W 115.020278 NAD27

8. WELL CONSTRUCTION  
 Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 50 Feet  
 From 6 Inches To 100 Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>129</u>	<u>.188</u>	<u>-1</u>	<u>100</u>

Perforations:  
 Type perforation mill  
 Size perforation ft 2.5" x 6.10w  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 60 feet to 100 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started July 30, 2022  
 Date completed Sept 20, 2022

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>20</u>	<u>1 hr</u>

RECEIVED  
 2007 OCT 19 AM 11:09

9. WATER LEVEL  
 Static water level 30 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 64 °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Maxnard Well Drilling Contractor  
 Address Po Box 64 Contractor  
Land NV 89317  
 Nevada contractor's license number issued by the State Contractor's Board 047226  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556  
 Signed Osam Maxnard  
 By driller performing actual drilling on site or contractor  
 Date Oct 17-07