

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Permit No. _____
 Basin 207

NOTICE OF INTENT NO. 59931

1. OWNER Boland Gardner ADDRESS AT WELL LOCATION 350 W 100 S
 MAILING ADDRESS Po Box 61 N 38° 51' 20.9"
Land NV 89317 W 115 00' 54.7"
 2. LOCATION NW 1/4 SW 1/4 Sec. 33 T 12 N/S R 62 E White Pine County
 PERMIT NO. N/A Issued by Water Resources Parcel No. 013-142-07 Subdivision Name Land Fam Dev plat

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty top soil		0	2.5	
Clay Hard pan		2.5	5	
Silt clay		5	8	
Sand	water	8	9	
Silt clay		9	17	
gravel	water	17	17.5	
Clay		17.5	41	
gravel	water	41	41.5	
Clay		41.5	53	
gravel	water	53	54	
Clay		54	57	
gravel	water	57	64	
Clay		64	77	
Clay-gravel		77	79	
Clay		79	83	
Sand gravel	water	83	85	
Silt Clay		85	100	

N 38.855806
W 115.015194 NAD27

8. WELL CONSTRUCTION
 Depth Drilled 100 Feet Depth Cased 100 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 53 Feet
6 Inches 53 Feet 100 Feet
 Inches Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>127</u>	<u>.188</u>	<u>1</u>	<u>100</u>

 Perforations:
 Type perforation mill
 Size perforation 1/8 & 2.5" x 6 row
 From _____ feet to _____ feet
 From 60 feet to 100 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 53 feet

Date started Sept 22, 2007
 Date completed Oct 8, 2007

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>28</u>	<u>1hr</u>

RECEIVED
 2007 OCT 19 AM 11:09

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Maynard Well Drilling Contractor
 Address Po Box 64 Contractor
Land NV 89317
 Nevada contractor's license number issued by the State Contractor's Board 047226
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
 Signed James Maynard
 By driller performing actual drilling on site or contractor
 Date Oct 17-07