STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104392
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59550

1. OWNER BERNEY REALTY
MAILING ADDRESS 290 W. WILLIAMS AVENUE
NE FALLON, NV 89406

ADDRESS AT WELL LOCATION 1202 VALLEY DRIVE
FALLON, NV 89406
Subdivision Name: County: CHURCHILL

2. LOCATION ~~SW~~ ¼ ~~NE~~ ¼ Sec 31 T 19N N/S R 29 E
PERMIT/WAIVER No. SE 010-133-01
Issued by Water Resources Parcel No.

Latitude 39.465083 Longitude 118.766064
UTM E 348071 N 4369669 [X] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[ ] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	10	9
BROWN CLAY		10	17	7
BROWN SANDS		17	30	13
BROWN SILT		30	40	10
BROWN CLAY		40	44	4
GRAY SANDS		44	60	16
GRAY CLAY		60	63	3
GRAY SANDS		63	83	20
BROWN CLAY		83	84	1
BROWN SANDS	X	84	95	11

Date started: 20-Jul , 20 07
Date completed: 20-Sep , 20 07

9. WELL CONSTRUCTION
Depth Drilled 95 Feet Depth Cased 95 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6	Inches	50	Feet	95	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	95

Perforations:
Type of perforation MACHINE SLIT
Size of perforation 0.18
From 87 feet to 93 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[X] Concrete Grout 0 to 50 [X] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:
Bentonite Chips: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 18'6" feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COOL °F
Quality: UNTESTED

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR LIFT	30		1 HR

STATE ENGINEERS OFFICE
2007 OCT 17 AM 10:55
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the *State Contractor's Board* 11752
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2199
Signed (By driller performing actual drilling on site or contractor)
Date 10/8/2007

(Rev. 05-08)
USE ADDITIONAL SHEETS IF NECESSARY