WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104398
Permit No.
Basin 070

MW-3

NOTICE OF INTENT NO. 46744

1. OWNER Pilot Travel Centers, LLC
MAILING ADDRESS 5508 Lonas Rd., Knoxville, Tennessee 37909

ADDRESS AT WELL LOCATION Former Unocal Station on the North side of off ramp at Exit 173 in Winnemucca

2. LOCATION SE ¼ SW ¼ Sec. 3 T. 35 N/S R. 37 E. Humboldt County

PERMIT NO. m/o 1443 (Issued by Water Resources) | Parcel No. 013-081-04 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand+Gravel	N/A	0'	3'	3'
silty sands	N/A	3'	15'	12'
Sand water at 15'		15'	30'	15'

N 40.931635
W 117.804015 NAD27

GPS
NAD 83 — 2839724.11 East (x) — 15375109.80 North (y)

RECEIVED 2007 MAR 22 PM 12:1 STATE ENGINEERS OFFICE

Date started 3-5-07, 20
Date completed 3-5-07, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED 2001 OCT 18 AM 10:54 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
8"	0'	30'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		sch 40	0'	10'

Perforations:
Type perforation Factory
Size perforation .020
From 10' feet to 30' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 8'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout Bentonite
Gravel Packed: ☒ Yes ☐ No
From 8' feet to 30' feet

9. WATER LEVEL
Static water level 15' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature <85 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Naz-Tech Drilling, Inc. (Contractor)
Address P.O. Box 940 (Contractor)
Meridian, Id. 83680
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1803
Signed (By driller performing actual drilling on site or contractor)
Date 3-14-07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627