STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104462
Permit No.
Basin 061

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59811

1. OWNER Newmont Mining Corporation
MAILING ADDRESS PO Box 669
Carlin, NV 89822

ADDRESS AT WELL LOCATION North Area
Hole #MW42-4A
Subdivision Name: County: Eureka

2. LOCATION NW ¼ NW ¼ Sec 3 T 35N N/S R 50 E
PERMIT/WAIVER No. NEV87065 Parcel No.
Issued by Water Resources

Latitude
Longitude
UTM E 555006 [x] NAD 27
N 4532810 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [x] RVC
[x] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	135	135

N40.916483
W 116.346505 NAD27

Date started: 11-Aug , 20 07
Date completed: 15-Aug , 20 07

9. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14 1/2	Inches	0	Feet	19	Feet
8 1/2	Inches	19	Feet	135	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"		.188	+1	19
4"		Sch 80 Screen	19	125
4"		Sch 80 Blank	125	135

Perforations:
Type of perforation Slotted
Size of perforation 0.02
From 105 feet to 125 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[x] Neat Cement 52 to 0 [x] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [x] Yes [ ] No 135 to 100 [x] Pumped [ ] Poured
Type: #8 Sand
Bentonite Chips: [x] Yes [ ] No 100 to 52 [ ] Pumped [x] Poured
Type: 3/8" Bentonite Chips

7. *Water Level*
Static water level: 92 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
-1		

STATE ENGINEERS OFFICE
2007 OCT 12 PM 2:43
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc.
Contractor
Address PO Box 2748
Contractor
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1776
Signed Arthur Steelman by (MW)
By driller performing actual drilling on site or contractor
Date 10/10/2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY