STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104464
Permit No.
Basin 061

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59813

1. OWNER Newmont Mining Corporation
MAILING ADDRESS PO Box 669
Carlin, NV 89822

ADDRESS AT WELL LOCATION North Area
Hole #MW42-14
Subdivision Name: County: Eureka

2. LOCATION SE ¼ SW ¼ Sec 32 T 36N N/S R 50 E
PERMIT/WAIVER No. NEV87065
Issued by Water Resources Parcel No.

Latitude 40.947730
Longitude 116.347146
UTM E 554951 [x] NAD 27
N 4532948 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [x] RVC
[x] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	115	115

Date started: 16-Aug , 20 07
Date completed: 22-Aug , 20 07

9. WELL CONSTRUCTION
Depth Drilled 115 Feet Depth Cased 115 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14 1/2	Inches	0	Feet	19	Feet
8 1/2"	Inches	19	Feet	115	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"		.188	+1	19
4"		Sch 80 Screen	19	105
4"		Sch 80 Blank	105	115

Perforations:
Type of perforation Slotted
Size of perforation 0.02
From 85 feet to 105 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[x] Neat Cement 54 to 0 [x] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [x] Yes [ ] No 85 to 70 [x] Pumped [ ] Poured
Type: #8 Sand
Bentonite Chips: [x] Yes [ ] No 70 to 54 [ ] Pumped [x] Poured
Type: 3/8" Bentonite Chips

7. Water Level
Static water level: Dry feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEERS OFFICE
2007 OCT 12 PM 2:43
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc.
Contractor
Address PO Box 2748
Contractor
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1776
Signed Arthur Steelman by [illegible]
By driller performing actual drilling on site or contractor
Date 10/10/2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY