

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52505

1. OWNER Walley Weister ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 5505 Cyanca Drive Winnemucca NV 89445
 2. LOCATION S 1/4 SW 1/4 Sec. 21 T. 36 N. R. 37 E.
 PERMIT NO. SW SE 10-01-18 Parcel No. _____
 Issued by Water Resources Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand/Clay		0	10	10
Sand Fine Gravel		10	20	10
Sand + Cobles		20	30	10
Course Gravel		30	90	30
Clay + Gravel		90	135	45
Cobles		135	160	25
Clay		160	210	50
Cobles		210	220	10
Clay Gravel		220	290	70
Sand + Gravel	<u>100 ft</u>	290	300	10
Course Sand Cobles		300	330	30
Clay		330	340	10

8. WELL CONSTRUCTION
 Depth Drilled 340 Feet Depth Cased 338 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 340 Feet
10 5/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>1 88</u>	<u>1</u>	<u>340</u>

Perforations:
 Type perforation Factory cut
 Size perforation 3/32 x 4
 From 298 feet to 338 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 338 feet

9. WATER LEVEL
 Static water level 197 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 66.1 °F Quality Fair

Date started 4-9, 2005
 Date completed 4-12, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>10-12</u>	<u>66.7</u>	<u>2:39</u>

2007 OCT 12 PM 2:39
RECEIVED
N40.97/146
W 117.81945 NAD02

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson Drilling Contractor
 Address 10760 Grass Valley Rd Contractor
Winn NV 89445
 Nevada contractor's license number issued by the State Contractor's Board. 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 2083
 Signed Ch...
 By driller performing actual drilling on site or contractor
 Date 4-20-05