

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54171

1. OWNER: Jeff McKovich ADDRESS AT WELL LOCATION: 231 Mount Grant Wellington NV
 MAILING ADDRESS: _____
 2. LOCATION: SE 1/4 SE 1/4 Sec 15 T 11 N/S R. 24 E Lyon County
 PERMIT NO. 009-20601 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED: New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE: Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE: Cable Rotary RVC Air Other mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|----------------------------------|--------------|--------|--------|-----------|
| Sand & Silt | | 0 | 30 | 30 |
| Sand & Clay Brown | | 30 | 78 | 48 |
| Sand & Gravel | | 78 | 93 | 15 |
| Clay Brown | | 93 | 219 | 126 |
| Gravel & Sand | ✓ | 219 | 230 | 11 |
| Blue Clay | ✓ | 230 | 290 | 60 |
| Coarse Sand mixed with fine sand | | 290 | 297 | 7 |
| Blue Clay | | 297 | 363 | 66 |
| Sand & Small Gravel | ✓ | 363 | 378 | 15 |
| 38° 46.782N | 38° | 48.713 | | |
| 119° 27.855W | 119 | 16.647 | WGS 84 | |
| N 38.811977 | | | | |
| W 119.276469 NAD27 | | | | |

8. WELL CONSTRUCTION ³⁷⁸
 Depth Drilled 378 Feet Depth Cased 390-4 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 378 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 3/8 | 13 | 1.88 | 0 | 18 |
| 6 5/8 | P.V.C. | SDR 21 | 18 | 378 |

Perforations:
 Type perforation Sauce
 Size perforation 1/8" 4"
 From _____ feet to _____ feet
 From 290 feet to 297 feet
 From _____ feet to _____ feet
 From 358 feet to 378 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 398 feet

9. WATER LEVEL
 Static water level 74 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature Cold °F Quality Good

Date started Nov 17 106, 20____
 Date completed Dec 7 106, 20____

7. WELL TEST DATA

| TEST METHOD: | Bailer | Pump | Air Lift |
|-------------------------------|-----------------------------|-----------------------------|-------------------------------------|
| | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Draw Down (Feet Below Static) | | | Time (Hours) |
| <u>62</u> | <u>55</u> | <u>4</u> | <u>2007 JAN 4 - NVT 1002</u> |
| <u>2007 OCT 10 AM 10:59</u> | <u>2007 OCT 10 AM 10:59</u> | <u>2007 OCT 10 AM 10:59</u> | <u>2007 OCT 10 AM 10:59</u> |
| RECEIVED | RECEIVED | RECEIVED | RECEIVED |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name: Lead Drilling Inc Contractor
 Address: P.O. Box 599 Silver Springs NV 89429 Contractor
 Nevada contractor's license number issued by the State Contractor's Board: 31841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1740
 Signed: Nathaniel Lead
 Date: Dec 16 106