

OFFICE USE ONLY
 Log No. 104782
 Permit No. _____
 Basin 776

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60877 ~~54088~~

1. OWNER SCOTT McCain ADDRESS AT WELL LOCATION 4520 GLENWOOD DRIVE EARLEY NV 89408
 MAILING ADDRESS 716 Earth Circle, Earley NV 89408
 2. LOCATION SE 1/4 NE 1/4 Sec. 25 T 20 (N) S R 25 E LYON County
 PERMIT NO. NE SW 021-501-25 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAY CLAY		450	520	
GRAY ROCK		520	560	
D.T.E		560	680	
CLAY & GRAVEL		680	720	

GPS: N 39° 34.006 W 6584
 W 119° 07.684

Deepening of log # 45741

N 39.566871
 W 119.127079 NAD83

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 760 Feet
 HOLE DIAMETER (BIT SIZE)
 From 674 Inches 450 Feet To 720 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5		180	265	720

Perforations:
 Type perforation FANTORY
 Size perforation _____
 From 680 feet to 700 feet
 From 690 feet to 660 feet
 From 600 feet to 620 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 280 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 90 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LEACH Drilling Inc. Contractor
 Address PO BOX 599 SILVER SPRINGS NV 89429 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 31841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2275
 Signed [Signature]
 Date 10-2-07
 By driller performing actual drilling on site or contractor

Date started 9-25, 2007
 Date completed 10-1, 2007

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>100'</u>	<u>8</u>	<u>30</u>	<u>12</u>

RECEIVED
 2007 OCT 10 AM 11:28