WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104483
Permit No.
Basin 107

NOTICE OF INTENT NO. 59391

1. OWNER James C. Euler & Patricia
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4 Harrison Dr Wellington NV

2. LOCATION NW ¼ SE ¼ Sec. 20 T. 11 N/S R. 24 E. Lyon County
PERMIT NO. (Issued by Water Resources) Parcel No. 10-511-20 Subdivision Name Smithvalley

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	20	20
Sand & gravel		20	140	120
gray clay & gravel		140	180	40
Brown clay + gravel		180	200	20
Big gravel & coarse sand		200	240	40

N 38.801293
W 119.317701 NAD27

N 38° 48.072
W 119° 19.127

RECEIVED 2007 MAR 30 AM 11:
STATE ENGINEERS OFFICE

Date started 3-26-07, 20
Date completed 3-28-07, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED 2007 OCT 10 AM 11:28 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	0	240

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	20
6		SDR21	20	240

Perforations:
Type perforation SAW cut
Size perforation 5/16
From feet to feet
From feet to feet
From 220 feet to 240 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 60 ft
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 60 feet to 240 feet

9. WATER LEVEL
Static water level 143' feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature COLD °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling (Contractor)
Address 13 x 599 Silversprings NV 89429 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878
Signed (By driller performing actual drilling on site or contractor)
Date 3-29-07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627