WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104489
Permit No. 68509
Basin 212

NOTICE OF INTENT NO. 31058

1. OWNER The Boyd Family Partnership
MAILING ADDRESS 2913 Silver Ave. LV. NV. 89102
ADDRESS AT WELL LOCATION SE corner of Severance + Jones

2. LOCATION SW ¼ SW ¼ Sec. 13 T. 19 S. N/S R. 60 E. Clark County
PERMIT NO. 68509 (Issued by Water Resources) 125-13-401-004 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☑ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		400	560	
Caliche w/ water	x	560	600	
Sandy Clay		600	640	
Caliche + water	x	640	705	

N 36° 17' 6.18
W 115° 13' 3.92
NAD 97

ong 105 # 42259

DCNR/DWR
RECEIVED
JAN 08 2008
LAS VEGAS OFFICE

Date started 08-30-07, 20
Date completed 09-05-07, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 705 Feet Depth Cased 705 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
~~9 7/8~~ Inches	Feet	Feet
7 7/8 Inches	400 Feet	705 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 1/2	PVC	480	+1	125
5	PVC	440	125	705

Perforations:
Type perforation Factory
Size perforation .032 Sieve Type
From 560 feet to 680 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 125 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick
Address 5360 N. Bonita Vista St. LV. NV. 89149 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed V. H. Dimick (By driller performing actual drilling on site or contractor)
Date 09-05-07

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627