WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY
026714

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

2 WELLS

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104505
Permit No.
Basin 212

NOTICE OF INTENT NO. 31493

1. OWNER C&C INVESTMENTS Co
MAILING ADDRESS 5505 E. CHARLESTON BLVD LAS VEGAS NV
ADDRESS AT WELL LOCATION 3505 E. CHARLESTON BLVD LAS VEGAS NV

2. LOCATION SW ¼ SW ¼ Sec. 31 T. 20 N/S R. 62 E. CLARK County
PERMIT NO. (Issued by Water Resources) Parcel No. 140-31-401-042 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & GRAVEL		0.0	8.0	8.0
SILTY CLAY		8.0	17.0	9.0
CLAY		17.0	25.0	8.0

MAP DATUM
WGS 84

MW-14 36°09.579N 115°05.846W
MW-15 36°09.618N 115°05.832W

NDEP #
8-000130

DCNR/DWR
RECEIVED
DEC 06 2007
LAS VEGAS OFFICE

Date started 12/04, 2007
Date completed 12/06, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8½ Inches	Feet	0 Feet	25 Feet
Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.0		SCH 40 PVC	25	0

Perforations:
Type perforation MACHINE SLOT
Size perforation .020
From 25 feet to 10 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 8'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 25 feet to 8 feet

9. WATER LEVEL
Static water level 17 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING SERVICES LLC (Contractor)
Address 7150 PEARIN ST (Contractor)
LAS VEGAS NV 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272
Signed (By driller performing actual drilling on site or contractor)
Date 12/06/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627