

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31826

1. OWNER Basic Environmental CO LLC ADDRESS AT WELL LOCATION N/A
~~HERFORD'S THE LANDRELL COMPANY~~
 MAILING ADDRESS 875 W. WARM Springs Rd NO physical address
HENDERSON, NV. 89011

2. LOCATION SE 1/4 NW 1/4 Sec. 5 T 22 N 063 E CIAAK County
 PERMIT NO. 17-000628 Parcel No. 179-05-401-001 Subdivision Name

NDPTAC # Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Light Brown Silty SAND		0'	5'	5'
Light Brown GRAVEL with silt & SAND		5'	15'	10'
Light Brown Red GRAVEL GRAVEL with silt & SAND		15'	25'	10'
Light Reddish Brown with SAND & GRAVEL		25'	30'	5'
Light Reddish BROWN well graded GRAVEL with silt & SAND		30'	35'	5'
Reddish GRAY GRAVEL with silt & SAND		35'	39'	4'
Light GRAY & Reddish Clay with GRAVEL & SAND		39'	45'	6'
Muddy CLAY GRAVEL silt & SAND	✓	45'	60'	15'

NAD 83
 838134.66238 E
 26722958.49642 N

Date started 08-07, 2007
 Date completed 08-07, 2007

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

DEC 3 2007

8. WELL CONSTRUCTION

Depth Drilled 60' Feet Depth Cased 60' Feet

HOLE DIAMETER (BIT SIZE)

From	To
8' Inches	0' Feet 60' Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	21.1/4	Sch 40 0.474"	+3	40

Perforations:

Type perforation Sch 40 Factory Cut
 Size perforation .020

From 40' feet to 60' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: 3/8 chips
 Depth of Seal 38'
 Neat Cement 2' 38'
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout 0-2'

Gravel Packed: Yes No
 From 38' feet to 60' feet

9. WATER LEVEL

Static water level 45.39' feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I. _____
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bart Longyear Co. Contractor
 Address 7773 W. Selden Lane Contractor
Peoria, AZ 85345

Nevada contractor's license number issued by the State Contractor's Board 0010157
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2148

Signed Phillip E. C.
 By driller performing actual drilling on site or contractor
 Date 8-21-07